

**CAUTION**  
Bonding between metallic  
conduit connections is not  
permitted.  
Separate bonding must be  
provided.

Grid Industries, Inc.  
Model No. 13  
INDOOR/OUTDOOR  
To maintain UL  
listing, all  
openings must be  
sealed with  
equipment cover  
sealant. Cover  
sealant must be  
applied to all  
No. 07 21284449

**UL**  
LISTED  
INDUSTRIAL  
CONTROL  
PANEL  
ENCLOSURE  
Type 1